## **Planned Event Work Order**

Print Date: 4/19/2012

WO#: 314092 SEMI-ANNUAL HIGH/LOW WATER LEVEL ALARM TEST

PE Number: 1632

Account: 049 - 049-Physical Plant Services Type: Planned Event Date Orig: 4/5/2012

Site: SOUTHSIDE VA TRAINING CENTER Priority: 3- PLANNED/PREVENTIVE MAINT Time Orig: 06:03:00

Building: MAIN GROUNDS Status: COMPLETED Due Date: 4/7/2012

Location: GROUNDS Sub-Status: (CHANGES ARE ALLOWED) Next Due Date: 10/7/2012

FACILITY GROUNDS - FACILITY GROUNDS Skill: ELECTRICIAN

Req Name: Req Phone: Req Email:

Req Remarks:

Resource #

Assignments

Resource Phone

DREWERYW DREWERY, WAYNE 524-4890

**Tasks** 

Task #: 10334 Desc: HIGH/LOW WATER LEVEL ALARM TEST

**Resource Name** 

Shut Down Required: No Est Time: 0.5 medTester: False

Type Task# **Date Created Instructions** Label Reading 4/19/2012 LOW LEVEL ALARM - DATE: DATE: 4/18/2012 Data Reading 10334 4/19/2012 **LEVEL** Data Reading **FEET** 11.2 10334 4/16/2012 10334 4/19/2012 HIGH LEVEL ALARM Data Reading DATE: 4/19/2012 I FVFI 32 10334 Data Reading **FEET** 4/19/2012 TEST COMPLETED AND PUMPS BACK IN AUTO Yes/No Reading 10334 Yes

Instructions:

HIGH/LOW WATER LEVEL ALARM TEST

Time Charges								
Resource #	Resource Name	Date	Hours	Cost	Comment			
DREWERYW	WAYNE DREWERY	4/19/2012	1	\$0.00	low alarm at level 11.2 ,high alarm 32.0			

Problem Code:Cause Code:Total Time:1Action Code:Item Code:Labor Cost:\$0.00

Material Cost: \$0.00

<b>Employee Code</b>	<b>Work Date</b>	First Name	Last Name	Regular Hours	Overtime Hours
TMS Reporting by Four Rivers S	Software Systems, Inc.				Page 1 of 2

## **Planned Event Work Order**

Print Date: 4/19/2012

WO#: 314092	SEMI-ANNUAL HIGH/LOW WATER LEVEL ALARM TEST						
Qty Used	Materials or Parts	Unit Cost	Total Cost				
wiy oseu	materials of Farts	Onit Gost	Total Gost				
		-					
Work Performed: _							
Signature:	Wo	rk Control Operator:	SYSTEM				