

ARWA Water Treatment Plant, PWSID # 4041035 Area : ARWA

ODW Sample Microbiological Report May 2012

Structure Set Name	Certifying Agency	Lab ID	Sample ID	PWSID	Sample Category	Classification Code	Sample Type	Compliance Indicator	Facility ID	Sampling Point	Sample Location	Collect Date	Collect Time	Receive Date	Sampler Name	CL2 Residual
sample	STATE	00005	12-402C	VA4041035	TC	TC	RT	Y	DS001	TCR01	020 Chesdin Rd. PS	05/01/2012	084900	05/01/2012	AH	3.7
sample	STATE	00005	12-403C	VA4041035	TC	TC	RT	Y	DS001	TCR01	030 DCWA PS	05/01/2012	091500	05/01/2012	AH	3.7
sample	STATE	00005	12-404C	VA4041035	TC	TC	RT	Y	DS001	TCR01	050 Petersburg Meter Vault	05/01/2012	093800	05/01/2012	AH	3.6
sample	STATE	00005	12-405C	VA4041035	TC	TC	RT	Y	DS001	TCR01	070 Temple Ave. Vault	05/01/2012	101400	05/01/2012	AH	3.6
sample	STATE	00005	12-406C	VA4041035	TC	TC	RT	Y	DS001	TCR01	080 Swift Creek Meter Vault	05/01/2012	103700	05/01/2012	AH	3.6
sample	STATE	00005	12-432C	VA4041035	TC	TC	RT	Y	DS001	TCR01	020 Chesdin Rd. PS	05/07/2012	091800	05/07/2012	AH	3.6
smample	STATE	00005	12-433C	VA4041035	TC	TC	RT	Y	DS001	TCR01	050 Petersburg Meter Vault	05/07/2012	094700	05/07/2012	AH	3.6
sample	STATE	00005	12-434C	VA4041035	TC	TC	RT	Y	DS001	TCR01	070 Temple Ave. Vault	05/07/2012	102000	05/07/2012	AH	3.6
sample	STATE	00005	12-435C	VA4041035	TC	TC	RT	Y	DS001	TCR01	080 Swift Creek Meter Vault	05/07/2012	104700	05/07/2012	AH	3.5
sample	STATE	00005	12-233R	VA4041035	TC	TC	RT	Y	DS001	TCR01	020 Chesdin Rd. PS	05/15/2015	094400	05/15/2015	AH	3.8
sample	STATE	00005	12-234R	VA4041035	TC	TC	RT	Y	DS001	TCR01	030 DCWA PS	05/15/2015	100800	05/15/2015	AH	3.6
sample	STATE	00005	12-235R	VA4041035	TC	TC	RT	Y	DS001	TCR01	050 Petersburg Meter Vault	05/15/2015	103100	05/15/2015	AH	3.7
sample	STATE	00005	12-236R	VA4041035	TC	TC	RT	Y	DS001	TCR01	070 Temple Ave. Vault	05/15/2015	111200	05/15/2015	AH	3.5
sample	STATE	00005	12-255R	VA4041035	TC	TC	RT	Y	DS001	TCR01	080 Swift Creek Meter Vault	05/16/2012	140000	05/16/2012	AH	3.7
sample	STATE	00005	12-479C	VA4041035	TC	TC	RT	Y	DS001	TCR01	020 Chesdin Rd. PS	05/21/2012	095400	05/21/2012	AH	3.9
sample	STATE	00005	12-480C	VA4041035	TC	TC	RT	Y	DS001	TCR01	040 Central State	05/21/2012	102600	05/21/2012	AH	3.3
sample	STATE	00005	12-481C	VA4041035	TC	TC	RT	Y	DS001	TCR01	050 Petersburg Meter Vault	05/21/2012	104700	05/21/2012	AH	3.8
sample	STATE	00005	12-482C	VA4041035	TC	TC	RT	Y	DS001	TCR01	080 Swift Creek Meter Vault	05/21/2012	113000	05/21/2012	AH	3.8
sample	STATE	00005	12-514C	VA4041035	TC	TC	RT	Y	DS001	TCR01	020 Chesdin Rd. PS	05/29/2012	092400	05/29/2012	AH	3.4
sample	STATE	00005	12-515C	VA4041035	TC	TC	RT	Y	DS001	TCR01	050 Petersburg Meter Vault	05/29/2012	103800	05/29/2012	AH	3.3
sample	STATE	00005	12-516C	VA4041035	TC	TC	RT	Y	DS001	TCR01	070 Temple Ave. Vault	05/29/2012	111400	05/29/2012	AH	3.2
sample	STATE	00005	12-517C	VA4041035	TC	TC	RT	Y	DS001	TCR01	080 Swift Creek Meter Vault	05/29/2012	120200	05/29/2012	AH	3.2