Southside Virginia Training Center Heating Plant Month Operations Report

5/31/2010 11:59 PM Monthly Report

Description

Description					
	Plant				Units
Heating Degree Days	81.75			hdd	
Total Plant Steam Flow	4,618.90				klbs
Steam Flow Per Heating Degree Day	56.5				klbs/hdd
Total Condensate Return Water Flow	169.9				klbs
Total Plant Gas Flow	5,662.19				kscf
Total Plant Gas Cost	\$62,643.81				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$62,643.81				\$
Fuel Cost Per Heating Degree Day	\$766.29				\$/hdd
Plant Average Steam Cost Per Degree Day	\$0.17				\$/klbs
Total Plant Efficiency By I/O	79.9				%
					T.
Condensate Transfer Pump #1 Run Time	157.4				hrs
Condensate Transfer Pump #2 Run Time	221.9				hrs
Condensate Transfer Pump #3 Run Time	363.5				hrs
Boiler Feed Pump #1 Run Time	184.3				hrs
Boiler Feed Pump #2 Run Time	232.0				hrs
Boiler Feed Pump #3 Run Time	148.6				hrs
Boiler Feed Pump #4 Run Time	178.1				hrs
Fuel Oil Pump #1 Run Time	1.0				hrs
Fuel Oil Pump #2 Run Time	1.1				hrs
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	259.7	1.2	310.0	169.6	hrs
Steam Flow	1656.77	3.04	1843.67	1115.42	klbs
Gas Flow	2025.65	12.13	2233.05	1391.36	kscf
Natural Gas Cost	\$22,410.77	\$134.19	\$24,705.48	\$15,393.37	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$22,410.77	\$134.19	\$24,705.48	\$15,393.37	\$
Average Steam Cost	\$13.53	\$44.14	\$13.40	\$13.80	\$/klbs
Efficiency By Losses	81.2	81.9	82.5	82.1	%
· ·	81.2			78.5	%
Efficiency By I/O	80.1	24.5	80.9	/8.5	70