## Southside Virginia Training Center Heating Plant Day Operations Report

2/29/2012 10:54 AM Monthly Report

## Description

		PI	ant		Units
Heating Degree Days	669.98				hdd
Total Plant Steam Flow	9,799.51			klbs	
Steam Flow Per Heating Degree Day	14.6				klbs/hd
Total Condensate Return Water Flow	151.0				klbs
Total Plant Gas Flow	11,492.32				kscf
Total Plant Gas Cost	\$79,319.97				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$79,319.97				\$
Fuel Cost Per Heating Degree Day	\$118.39				\$/hdd
Plant Average Steam Cost Per Degree Day	\$0.01				\$/klbs
Total Plant Efficiency By I/O	83.5				%
Condensate Transfer Pump #1 Run Time		24			hrs
Condensate Transfer Pump #1 Run Time	246.4				hrs
Condensate Transfer Pump #2 Run Time	288.1				hrs
Boiler Feed Pump #1 Run Time	200.1				hrs
Boiler Feed Pump #2 Run Time	155.1				hrs
Boiler Feed Pump #2 Run Time	266.1				hrs
Boiler Feed Pump #4 Run Time	35.7				hrs
Fuel Oil Pump #1 Run Time	0.1				hrs
Fuel Oil Pump #2 Run Time	0.1				hrs
		· · · · ·	. 1		1113
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	310.5	230.2	175.3	0.0	hrs
Steam Flow	4089.39	3298.09	2412.03	0.00	klbs
Gas Flow	4563.99	4144.08	2784.25	0.00	kscf
Natural Gas Cost	\$31,500.65	\$28,602.40	\$19,216.92	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$31,500.65	\$28,602.40	\$19,216.92	\$0.00	\$
Average Steam Cost	\$7.70	\$8.67	\$7.97		\$/klbs
Efficiency By Losses	83.2	77.5	82.5		%
Efficiency By I/O	87.7	77.9	84.8		%