

Central State Hospital
Heating Plant Day Operations Report

4/1/2021
7:00 AM
Daily Report

Description

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	328.42				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	403.41				kscf
Total Plant Gas Cost	\$2,477.24				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$2,477.24				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	79.7				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.8	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	328.42	0.00	klbs
Gas Flow	0.00	0.00	403.41	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$2,477.24	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$2,477.24	\$0.00	\$
Average Steam Cost	---	---	\$7.54	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O	79.7				%

Central State Hospital
Heating Plant Day Operations Report

4/2/2021
7:01 AM
Daily Report

Description

	Plant				Units
Heating Degree Days	38.42				hdd
Total Plant Steam Flow	358.41				klbs
Steam Flow Per Heating Degree Day	9.3				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	413.78				kscf
Total Plant Gas Cost	\$2,540.94				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$2,540.94				\$
Fuel Cost Per Heating Degree Day	\$66.13				\$/hdd
Plant Average Steam Cost Per Degree Day	\$0.18				\$/klbs
Total Plant Efficiency By I/O	84.8				%
<hr/>					
Condensate Transfer Pump #1 Run Time	11.4				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	11.4				hrs
Boiler Feed Pump #1 Run Time	11.4				hrs
Boiler Feed Pump #2 Run Time	11.4				hrs
Boiler Feed Pump #3 Run Time	11.4				hrs
Boiler Feed Pump #4 Run Time	11.4				hrs
Fuel Oil Pump #1 Run Time	11.4				hrs
Fuel Oil Pump #2 Run Time	11.4				hrs
<hr/>					
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.9	0.0	23.5	0.6	hrs
Steam Flow	0.00	0.00	358.41	0.00	klbs
Gas Flow	1.96	0.00	410.47	1.36	kscf
Natural Gas Cost	\$12.04	\$0.00	\$2,520.57	\$8.34	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$12.04	\$0.00	\$2,520.57	\$8.34	\$
Average Steam Cost	---	---	\$7.03	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O	85.5				%

Central State Hospital
Heating Plant Day Operations Report

4/3/2021
7:00 AM
Daily Report

Description

	Plant	Units
Heating Degree Days	0.00	hdd
Total Plant Steam Flow	359.24	klbs
Steam Flow Per Heating Degree Day	---	klbs/hdd
Total Condensate Return Water Flow	0.0	klbs
Total Plant Gas Flow	422.07	kscf
Total Plant Gas Cost	\$2,591.83	\$
Total Plant Oil Flow	0.0	gals
Total Plant Oil Cost	\$0.00	\$
Total Plant Fuel Cost	\$2,591.83	\$
Fuel Cost Per Heating Degree Day	---	\$/hdd
Plant Average Steam Cost Per Degree Day	---	\$/klbs
Total Plant Efficiency By I/O	83.4	%

Condensate Transfer Pump #1 Run Time	0.0	hrs
Condensate Transfer Pump #2 Run Time	0.0	hrs
Condensate Transfer Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #1 Run Time	0.0	hrs
Boiler Feed Pump #2 Run Time	0.0	hrs
Boiler Feed Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #4 Run Time	0.0	hrs
Fuel Oil Pump #1 Run Time	0.0	hrs
Fuel Oil Pump #2 Run Time	0.0	hrs

	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.8	0.0	23.5	0.7	hrs
Steam Flow	0.00	0.00	359.24	0.00	klbs
Gas Flow	0.00	0.00	422.07	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$2,591.83	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$2,591.83	\$0.00	\$
Average Steam Cost	---	---	\$7.21	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O			83.4		%

Central State Hospital
Heating Plant Day Operations Report

4/4/2021
7:00 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	359.21	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	422.04	kscf			
Total Plant Gas Cost	\$2,591.61	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$2,591.61	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	83.4	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.7	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	359.21	0.00	klbs
Gas Flow	0.00	0.00	422.04	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$2,591.61	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$2,591.61	\$0.00	\$
Average Steam Cost	---	---	\$7.21	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O			83.4		%

Central State Hospital
Heating Plant Day Operations Report

4/5/2021
7:00 AM
Daily Report

Description

	Plant	Units
Heating Degree Days	0.00	hdd
Total Plant Steam Flow	359.24	klbs
Steam Flow Per Heating Degree Day	—	klbs/hdd
Total Condensate Return Water Flow	0.0	klbs
Total Plant Gas Flow	422.02	kscf
Total Plant Gas Cost	\$2,591.49	\$
Total Plant Oil Flow	0.0	gals
Total Plant Oil Cost	\$0.00	\$
Total Plant Fuel Cost	\$2,591.49	\$
Fuel Cost Per Heating Degree Day	---	\$/hdd
Plant Average Steam Cost Per Degree Day	—	\$/klbs
Total Plant Efficiency By I/O	83.4	%

Condensate Transfer Pump #1 Run Time	0.0	hrs
Condensate Transfer Pump #2 Run Time	0.0	hrs
Condensate Transfer Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #1 Run Time	0.0	hrs
Boiler Feed Pump #2 Run Time	0.0	hrs
Boiler Feed Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #4 Run Time	0.0	hrs
Fuel Oil Pump #1 Run Time	0.0	hrs
Fuel Oil Pump #2 Run Time	0.0	hrs

	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.7	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	359.24	0.00	klbs
Gas Flow	0.00	0.00	422.02	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$2,591.49	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$2,591.49	\$0.00	\$
Average Steam Cost	—	—	\$7.21	—	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O			83.4		%

Central State Hospital
Heating Plant Day Operations Report

4/6/2021
7:00 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	359.23	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	422.05	kscf			
Total Plant Gas Cost	\$2,591.72	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$2,591.72	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	83.4	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.9	0.0	23.5	0.4	hrs
Steam Flow	0.00	0.00	359.23	0.00	klbs
Gas Flow	0.00	0.00	422.05	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$2,591.72	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$2,591.72	\$0.00	\$
Average Steam Cost	---	---	\$7.21	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O			83.4		%

Central State Hospital
Heating Plant Day Operations Report

4/7/2021
7:01 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	359.21	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	422.03	kscf			
Total Plant Gas Cost	\$2,591.59	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$2,591.59	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	83.4	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.7	0.0	23.5	0.4	hrs
Steam Flow	0.00	0.00	359.21	0.00	klbs
Gas Flow	0.00	0.00	422.03	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$2,591.59	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$2,591.59	\$0.00	\$
Average Steam Cost	---	---	\$7.21	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O			83.4		%

Central State Hospital
Heating Plant Day Operations Report

4/8/2021
7:01 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	359.23	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	422.05	kscf			
Total Plant Gas Cost	\$2,591.72	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$2,591.72	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	83.4	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.6	0.0	23.5	0.4	hrs
Steam Flow	0.00	0.00	359.23	0.00	klbs
Gas Flow	0.00	0.00	422.05	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$2,591.72	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$2,591.72	\$0.00	\$
Average Steam Cost	---	---	\$7.21	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O			83.4		%

Central State Hospital
Heating Plant Day Operations Report

4/10/2021
7:00 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	107.34	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.8	0.0	23.2	0.4	hrs
Steam Flow	0.00	0.00	107.34	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	\$0.00	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/11/2021
7:00 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.8	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/12/2021
7:00 AM
Daily Report

Description

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.8	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/13/2021
7:00 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.8	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/14/2021
7:00 AM
Daily Report

Description

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.8	0.0	23.5	0.6	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/15/2021
7:00 AM
Daily Report

Description

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.7	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/16/2021
7:00 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.9	0.0	23.5	0.7	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/17/2021
7:00 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.9	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/18/2021
7:01 AM
Daily Report

Description

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.8	0.0	23.5	0.6	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/19/2021
7:00 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.8	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/20/2021
7:00 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.9	0.0	23.5	0.7	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O	---	---	---	---	%

Central State Hospital
Heating Plant Day Operations Report

4/21/2021
7:00 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.7	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/22/2021
7:01 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	—	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	—	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	—	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	1.0	0.0	23.5	0.7	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	—	—	—	—	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/23/2021
7:01 AM
Daily Report

Description

	Plant	Units
Heating Degree Days	0.00	hdd
Total Plant Steam Flow	0.00	klbs
Steam Flow Per Heating Degree Day	—	klbs/hdd
Total Condensate Return Water Flow	0.0	klbs
Total Plant Gas Flow	0.00	kscf
Total Plant Gas Cost	\$0.00	\$
Total Plant Oil Flow	0.0	gals
Total Plant Oil Cost	\$0.00	\$
Total Plant Fuel Cost	\$0.00	\$
Fuel Cost Per Heating Degree Day	---	\$/hdd
Plant Average Steam Cost Per Degree Day	---	\$/klbs
Total Plant Efficiency By I/O	—	%

Condensate Transfer Pump #1 Run Time	0.0	hrs
Condensate Transfer Pump #2 Run Time	0.0	hrs
Condensate Transfer Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #1 Run Time	0.0	hrs
Boiler Feed Pump #2 Run Time	0.0	hrs
Boiler Feed Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #4 Run Time	0.0	hrs
Fuel Oil Pump #1 Run Time	0.0	hrs
Fuel Oil Pump #2 Run Time	0.0	hrs

	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	1.0	0.0	23.5	0.6	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	—	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/28/2021
7:00 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.7	0.0	23.1	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/29/2021
7:00 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.8	0.0	23.5	0.4	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

Central State Hospital
Heating Plant Day Operations Report

4/30/2021
7:00 AM
Daily Report

Description

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.7	0.0	23.5	0.4	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%