

**Central State Hospital**  
Heating Plant Day Operations Report

5/1/2021  
7:00 AM  
Daily Report

**Description**

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	0.9	0.0	23.5	0.6	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/2/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	0.8	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/3/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	0.6	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/4/2021  
7:00 AM  
Daily Report

**Description**

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.8	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/5/2021  
7:00 AM  
Daily Report

**Description**

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	0.7	0.0	23.5	0.4	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/6/2021  
7:00 AM  
Daily Report

**Description**

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	0.8	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/7/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	—	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	—	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	0.8	0.0	23.5	0.6	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	—	—	—	—	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O	0.0	0.0	0.0	0.0	%

**Central State Hospital**  
Heating Plant Day Operations Report

5/8/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	0.9	0.0	23.5	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%



**Central State Hospital**  
Heating Plant Day Operations Report

5/9/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	0.9	0.0	23.5	0.4	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/10/2021  
7:00 AM  
Daily Report

**Description**

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.7	0.0	23.5	0.4	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/11/2021  
7:01 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	21.7	0.0	2.5	0.0	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/12/2021  
7:01 AM  
Daily Report

**Description**

	<b>Plant</b>				<b>Units</b>
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	23.5	0.0	0.0	0.0	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/13/2021  
8:01 AM  
Daily Report

**Description**

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	0.5	0.0	0.0	0.0	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/15/2021  
7:00 AM  
Daily Report

**Description**

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	23.2	0.0	0.0	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/16/2021  
7:00 AM  
Daily Report

**Description**

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	23.5	0.0	0.0	0.6	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/17/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	23.5	0.0	0.0	0.4	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%



**Central State Hospital**  
Heating Plant Day Operations Report

5/18/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	23.5	0.0	0.0	0.6	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/19/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	23.5	0.0	0.0	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/20/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units
Heating Degree Days	0.00	hdd
Total Plant Steam Flow	0.00	klbs
Steam Flow Per Heating Degree Day	---	klbs/hdd
Total Condensate Return Water Flow	0.0	klbs
Total Plant Gas Flow	0.00	kscf
Total Plant Gas Cost	\$0.00	\$
Total Plant Oil Flow	0.0	gals
Total Plant Oil Cost	\$0.00	\$
Total Plant Fuel Cost	\$0.00	\$
Fuel Cost Per Heating Degree Day	---	\$/hdd
Plant Average Steam Cost Per Degree Day	---	\$/klbs
Total Plant Efficiency By I/O	---	%

Condensate Transfer Pump #1 Run Time	0.0	hrs
Condensate Transfer Pump #2 Run Time	0.0	hrs
Condensate Transfer Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #1 Run Time	0.0	hrs
Boiler Feed Pump #2 Run Time	0.0	hrs
Boiler Feed Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #4 Run Time	0.0	hrs
Fuel Oil Pump #1 Run Time	0.0	hrs
Fuel Oil Pump #2 Run Time	0.0	hrs

	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	23.5	0.9	0.0	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/21/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	23.5	0.0	0.0	0.5	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/22/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	23.5	0.0	0.0	0.6	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/23/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units
Heating Degree Days	0.00	hdd
Total Plant Steam Flow	0.00	klbs
Steam Flow Per Heating Degree Day	---	klbs/hdd
Total Condensate Return Water Flow	0.0	klbs
Total Plant Gas Flow	0.00	kscf
Total Plant Gas Cost	\$0.00	\$
Total Plant Oil Flow	0.0	gals
Total Plant Oil Cost	\$0.00	\$
Total Plant Fuel Cost	\$0.00	\$
Fuel Cost Per Heating Degree Day	---	\$/hdd
Plant Average Steam Cost Per Degree Day	---	\$/klbs
Total Plant Efficiency By I/O	---	%

Condensate Transfer Pump #1 Run Time	0.0	hrs
Condensate Transfer Pump #2 Run Time	0.0	hrs
Condensate Transfer Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #1 Run Time	0.0	hrs
Boiler Feed Pump #2 Run Time	0.0	hrs
Boiler Feed Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #4 Run Time	0.0	hrs
Fuel Oil Pump #1 Run Time	0.0	hrs
Fuel Oil Pump #2 Run Time	0.0	hrs

	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	23.5	0.0	0.0	0.3	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/24/2021  
7:00 AM  
Daily Report

**Description**

	Plant				Units
Heating Degree Days	0.00				hdd
Total Plant Steam Flow	0.00				klbs
Steam Flow Per Heating Degree Day	---				klbs/hdd
Total Condensate Return Water Flow	0.0				klbs
Total Plant Gas Flow	0.00				kscf
Total Plant Gas Cost	\$0.00				\$
Total Plant Oil Flow	0.0				gals
Total Plant Oil Cost	\$0.00				\$
Total Plant Fuel Cost	\$0.00				\$
Fuel Cost Per Heating Degree Day	---				\$/hdd
Plant Average Steam Cost Per Degree Day	---				\$/klbs
Total Plant Efficiency By I/O	---				%
Condensate Transfer Pump #1 Run Time	0.0				hrs
Condensate Transfer Pump #2 Run Time	0.0				hrs
Condensate Transfer Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #1 Run Time	0.0				hrs
Boiler Feed Pump #2 Run Time	0.0				hrs
Boiler Feed Pump #3 Run Time	0.0				hrs
Boiler Feed Pump #4 Run Time	0.0				hrs
Fuel Oil Pump #1 Run Time	0.0				hrs
Fuel Oil Pump #2 Run Time	0.0				hrs
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	23.5	0.0	0.0	0.4	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/25/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	23.2	0.0	0.0	0.7	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%



**Central State Hospital**  
Heating Plant Day Operations Report

5/26/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	23.5	0.0	0.0	0.4	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/27/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	<b>Boiler 1</b>	<b>Boiler 2</b>	<b>Boiler 3</b>	<b>Boiler 4</b>	<b>Units</b>
Run Time	23.4	1.3	0.0	0.4	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/28/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units
Heating Degree Days	0.00	hdd
Total Plant Steam Flow	0.00	klbs
Steam Flow Per Heating Degree Day	---	klbs/hdd
Total Condensate Return Water Flow	0.0	klbs
Total Plant Gas Flow	0.00	kscf
Total Plant Gas Cost	\$0.00	\$
Total Plant Oil Flow	0.0	gals
Total Plant Oil Cost	\$0.00	\$
Total Plant Fuel Cost	\$0.00	\$
Fuel Cost Per Heating Degree Day	---	\$/hdd
Plant Average Steam Cost Per Degree Day	---	\$/klbs
Total Plant Efficiency By I/O	---	%

Condensate Transfer Pump #1 Run Time	0.0	hrs
Condensate Transfer Pump #2 Run Time	0.0	hrs
Condensate Transfer Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #1 Run Time	0.0	hrs
Boiler Feed Pump #2 Run Time	0.0	hrs
Boiler Feed Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #4 Run Time	0.0	hrs
Fuel Oil Pump #1 Run Time	0.0	hrs
Fuel Oil Pump #2 Run Time	0.0	hrs

	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	23.5	0.0	0.0	0.4	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/29/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units			
Heating Degree Days	0.00	hdd			
Total Plant Steam Flow	0.00	klbs			
Steam Flow Per Heating Degree Day	---	klbs/hdd			
Total Condensate Return Water Flow	0.0	klbs			
Total Plant Gas Flow	0.00	kscf			
Total Plant Gas Cost	\$0.00	\$			
Total Plant Oil Flow	0.0	gals			
Total Plant Oil Cost	\$0.00	\$			
Total Plant Fuel Cost	\$0.00	\$			
Fuel Cost Per Heating Degree Day	---	\$/hdd			
Plant Average Steam Cost Per Degree Day	---	\$/klbs			
Total Plant Efficiency By I/O	---	%			
Condensate Transfer Pump #1 Run Time	0.0	hrs			
Condensate Transfer Pump #2 Run Time	0.0	hrs			
Condensate Transfer Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #1 Run Time	0.0	hrs			
Boiler Feed Pump #2 Run Time	0.0	hrs			
Boiler Feed Pump #3 Run Time	0.0	hrs			
Boiler Feed Pump #4 Run Time	0.0	hrs			
Fuel Oil Pump #1 Run Time	0.0	hrs			
Fuel Oil Pump #2 Run Time	0.0	hrs			
	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	23.5	1.6	0.0	0.4	hrs
Steam Flow	0.00	0.00	0.00	0.00	klbs
Gas Flow	0.00	0.00	0.00	0.00	kscf
Natural Gas Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	---	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O					%

**Central State Hospital**  
Heating Plant Day Operations Report

5/30/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units
Heating Degree Days	39.30	hdd
Total Plant Steam Flow	103.95	klbs
Steam Flow Per Heating Degree Day	2.6	klbs/hdd
Total Condensate Return Water Flow	0.0	klbs
Total Plant Gas Flow	119.79	kscf
Total Plant Gas Cost	\$735.60	\$
Total Plant Oil Flow	0.0	gals
Total Plant Oil Cost	\$0.00	\$
Total Plant Fuel Cost	\$735.60	\$
Fuel Cost Per Heating Degree Day	\$18.72	\$/hdd
Plant Average Steam Cost Per Degree Day	\$0.18	\$/klbs
Total Plant Efficiency By I/O	85.0	%

Condensate Transfer Pump #1 Run Time	7.3	hrs
Condensate Transfer Pump #2 Run Time	7.3	hrs
Condensate Transfer Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #1 Run Time	7.3	hrs
Boiler Feed Pump #2 Run Time	7.3	hrs
Boiler Feed Pump #3 Run Time	7.3	hrs
Boiler Feed Pump #4 Run Time	7.3	hrs
Fuel Oil Pump #1 Run Time	7.4	hrs
Fuel Oil Pump #2 Run Time	0.0	hrs

	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	23.5	1.3	0.0	0.8	hrs
Steam Flow	103.94	0.00	0.00	0.01	klbs
Gas Flow	116.90	1.46	0.03	1.40	kscf
Natural Gas Cost	\$717.83	\$8.99	\$0.17	\$8.62	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$717.83	\$8.99	\$0.17	\$8.62	\$
Average Steam Cost	\$6.91	---	---	\$585.97	\$/klbs
Efficiency By Losses	81.3	73.3	0.0	73.5	%
Efficiency By I/O	87.1			1.0	%

**Central State Hospital**  
Heating Plant Day Operations Report

5/31/2021  
7:00 AM  
Daily Report

**Description**

	Plant	Units
Heating Degree Days	0.00	hdd
Total Plant Steam Flow	225.06	klbs
Steam Flow Per Heating Degree Day	---	klbs/hdd
Total Condensate Return Water Flow	0.0	klbs
Total Plant Gas Flow	256.06	kscf
Total Plant Gas Cost	\$1,572.39	\$
Total Plant Oil Flow	0.0	gals
Total Plant Oil Cost	\$0.00	\$
Total Plant Fuel Cost	\$1,572.39	\$
Fuel Cost Per Heating Degree Day	---	\$/hdd
Plant Average Steam Cost Per Degree Day	---	\$/klbs
Total Plant Efficiency By I/O	86.1	%

Condensate Transfer Pump #1 Run Time	0.0	hrs
Condensate Transfer Pump #2 Run Time	0.0	hrs
Condensate Transfer Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #1 Run Time	0.0	hrs
Boiler Feed Pump #2 Run Time	0.0	hrs
Boiler Feed Pump #3 Run Time	0.0	hrs
Boiler Feed Pump #4 Run Time	0.0	hrs
Fuel Oil Pump #1 Run Time	0.0	hrs
Fuel Oil Pump #2 Run Time	0.0	hrs

	Boiler 1	Boiler 2	Boiler 3	Boiler 4	Units
Run Time	23.5	1.4	0.0	0.6	hrs
Steam Flow	225.06	0.00	0.00	0.00	klbs
Gas Flow	256.06	0.00	0.00	0.00	kscf
Natural Gas Cost	\$1,572.39	\$0.00	\$0.00	\$0.00	\$
Oil Flow	0.0	0.0	0.0	0.0	gals
Oil Cost	\$0.00	\$0.00	\$0.00	\$0.00	\$
Total Fuel Cost	\$1,572.39	\$0.00	\$0.00	\$0.00	\$
Average Steam Cost	\$6.99	---	---	---	\$/klbs
Efficiency By Losses	0.0	0.0	0.0	0.0	%
Efficiency By I/O	86.1				%